

Water Services Planning Report

Register Reference No.: SD22A/0065

Development: Provision of a warehouse unit with ancillary office and staff facilities and associated development. The building will have a maximum height of 15.5m with a gross floor area of 13,604sq.m including a warehouse area (12,568sq.m), staff facilities (489sq.m) and ancillary office area (538sq.m). The development will also include a vehicular and pedestrian entrance to the site from Magna Avenue, a separate HGV entrance from Magna Drive; 69 ancillary car parking spaces; covered bicycle parking; HGV parking and yards'; level access good doors; dock levellers; access gates; signage; hard and soft landscaping; lighting boundary treatments; ESB substation; sprinkler tank and pump house; an all associated site development works above and below ground.

Location: Magna Avenue and Magna Drive, Citywest, Dublin 24

Report Date : 30th Mar 2022

Surface Water Report:

No Objection Subject To:

1 Prior to commencement of development submit a revised drawing showing swales with an overflow connection to the surface water system as part of SuDS (Sustainable Drainage System).

Flood Risk

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____