

Water Services Planning Report

Register Reference: SD22B/0079
Development: Retention for detached single storey shed/gym/office to the rear of the garden with ancillary works.
Location: 23, Churchview, Gibraltar, Dublin 22
Applicant: Anthony Sterio
App. Type: Retention
Date Received: 22-Feb-2022
Report Date: 30th March 2022

Surface Water Report:

Further Information Required:

- 1.1** There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.
- 1.2** The applicant is required to submit a revised drawing showing plan and cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
- i) At least 5m from any building, public sewer, road boundary or structure.
 - ii) Generally, not within 3m of the boundary of the adjoining property.
 - iii) Not in such a position that the ground below foundations is likely to be adversely affected.
 - iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
 - v) Soakaways must include an overflow connection to the surface water drainage network.
- 1.3** The applicant is required to submit a drawing in plan and cross sectional views clearly showing additional proposed Sustainable Drainage Systems (SuDS) features for the development such as green roofs ,water butts and rain planter boxes.
- 1.4** The applicant is required to submit a drawing showing existing and proposed surface water drainage layouts up to and including the point of connection to the public surface water sewer. The drawing shall include the location of all Aj's, manholes, pipe size, material type and direction of flow. The drawing shall clearly show that the foul and surface water systems are discharging to separate pipe networks. Maps of the mains foul and surface water drainage networks may be obtained, if available, for required locations in South Dublin County Council by emailing: servicemaps@sdublincoco.ie.

Water Services Planning Report

- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____