

Water Services Planning Report

Register Reference: SD22B/0088
Development: New single storey ground floor extension to the rear elevation including internal ground and first floor plan alterations; new ground and first floor extension to the front/side elevation; fenestration alterations to the front first floor landing window and ground floor entrance door; roof alterations required for first side extension including conversion of existing and proposed attic spaces with roof dormer to the rear elevation for the provision of a bedroom, ensuite bathroom and attic storage at second level and roof windows to the front elevation ; including the widening of existing vehicular entrance onto Whitehall Road and all associated site works.
Location: 37, Whitehall Road, Dublin 12
Applicant: Lisa and Fergal Griffin
App. Type: Permission
Date Received: 25-Feb-2022
Report Date: 1st April 2022

Surface Water Report:

Further Information Required:

- 1.1** The applicant has not submitted surface water drainage plans for the proposed development. The applicant is required to submit a drawing showing existing and proposed surface water drainage layouts up to and including the point of connection to the public surface water sewer. The drawing shall include the location of all AJs, manholes, pipe size, material type and direction of flow. The drawing shall clearly show that the foul and surface water systems are discharging to separate pipe networks. Maps of the mains foul and surface water drainage networks may be obtained, if available, for required locations in South Dublin County Council by emailing: servicemaps@sdublincoco.ie.
- 1.2** The applicant is required to submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development.

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Services Planning Report

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____