GENERAL NOTES

1. This Drawing is to be read in conjunction with all the Engineer's and Architect's Drawings and Specifications.
2. Do Not Scale. Use Figured Dimensions Only. Refer to the Architects Drawings for all setting out dimensions.
3. All Dimensions To Be Checked on-site. Engineer and Architect to be informed immediately of any discrepancies between the condition/ situation on site and that assumed on the Project Design Drawings.
4. IF IN DOUBT ASK.

N

SO05290501
CL 79.03
IL 76.62

SO05290401
CL 79.56
IL 77.56

SO04299401
CL 80.47
IL 78.59

SO04299301
CL 81.77
IL 79.95

SO04298201
CL 82.84
IL 80.92

SO04298201
CL 83.74
IL 81.93

SO04298102
CL 84.8
IL 82.39

OWNERSHIP/ SITE BOUNDARY

PROPOSED CONNECTION TO 675 DIA. PUBLIC SEWER

PROVIDE DOUBLE SEALED MH COVER IN FLOOD ZONE TO PREVENT POTENTIAL FLOOD WATER INGRESS

CAMAC RIVER

KINGSWOOD PL1

MONEENALION

MONEENALION MID

MONEENALION W

MONEENALION STH.

NEW TRAINING PITCH (ON-GRADE)

NEW BACK PITCH (ON-GRADE)

NEW MAIN PITCH

NEW JUNIOR PITCH

NEW CRFC CLUBHOUSE PAVILION

FFL 85.78

EX. RFL 85.28

AGRI. SHED (CONVERT TO CHANGING ROOMS)

35/25 AGHD

160mm PVC-A

200mm PVC-A

200mm Ductile Iron

2 x 100PP
1 x 3-way MD
1 x 100CD

2 x 100PP
1 x 3-way MD
1 x 3.5inch

4 x 100PP
2 x 3-way MD

2 x 3-way MD
3 x 225CD

NWL1

PVC-U 150 Ø FW @ 1/100

150 Ø FW @ 1/100

150 Ø AW @ 0.6%

675CO

1 PROPOSED FOUL WATER SITE SERVICES

1:1000

A1

ESB COLOUR CODE

- ESB — GREEN - MV (10KV/20KV) OVERHEAD LINES
- ESB — CYAN - 38KV & HIGHER VOLTAGE UNDERGROUND CABLE ROUTES
- ESB — RED - MV/LV (10KV/20KV/400V/230V) UNDERGROUND CABLE ROUTES

GAS COLOUR CODE

- GAS — TRANSMISSION PIPE (HIGH PRESSURE)
- GAS — AURORA TELECOM SUB DUCT

WATER COLOUR CODE

- WM — IRISH WATER - WATER MAINS
- FW — GRAVITY - FOUL

EIRCOM COLOUR CODE

- COM — OPEN EIR SERVICE

NB NOTE: ALL PIPEWORK CONNECTIONS, MANHOLES, ACCESS CHAMBERS AND ANCILLARY COMPONENTS TO BE STRICTLY IN ACCORDANCE WITH IRISH WATER'S WATER INFRASTRUCTURE STANDARD DETAILS: CONNECTIONS AND DEVELOPER SERVICES DATED JULY 2020((Rev 4), DOCUMENT REF. IW-CDS-5030-01

Rev.	Description	By	Date
P12	ISSUED ISSUED FOR PLANNING	SCM	24/02/2022

Drawn By / Date	SCM	FEBRUARY 2022	Approved for Construction by:
Drawing Chk / Date			
Design By / Date	SCE	FEBRUARY 2022	
Design Chk / Date			

* Refer to Suitability "S4" for Original Signatures

SEXTON CONSULTING
The Five Roads, Jordanstown, Lusk, North County Dublin, Ireland, K45 NY74
t +353-1-8490999. e connect@sceg.ie

Client: CLONDALKIN RUGBY FOOTBALL CLUB LTD

Architect: CUMMINS & VOORTMAN ARCHITECTS

Project: CRFC KINGSWOOD RELOCATION
KINGSWOOD FARM MONEENALION COMMONS LOWER CLONDALKIN D22

Title: PROPOSED FOUL WATER SEWER

Job No.: SC04/21020

Creation: FEBRUARY 2022

Project Code: CRFC - SC - FW - 00 - DR - C - 2001
(Project Code | Originator | Volume | Level | Type | Role | Number)

Suitability: Issued for Planning

Code: S2

Revison ID: P12

Status: PLANNING

THIS DRAWING IS COPYRIGHT © ALL RIGHTS RESERVED. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE PRIOR WRITTEN PERMISSION FROM SCEG LIMITED T/A SEXTON CONSULTING.