

# Water Services Planning Report

**Register Reference No.:** SD22A/0072  
**Development:** Retention permission for 'Click and Collect' signage in the existing Tesco car park; and (ii) permission for the construction of a sheltered canopy (c50 sq.m) in the existing car park for the purpose of providing 2 dedicated 'Click and Collect' spaces for the existing Tesco store and all associated site development works.  
**Location:** Above ground installation at Grange Castle Business Park, Nangor Road, Clondalkin, Dublin 22  
**Report Date :** 7<sup>th</sup> April 2022

---

## Surface Water Report:

## **Further Information Required:**

1 Submit a drawing showing the distance between foundation of proposed signs and any adjacent surface water sewers.

## **Flood Risk**

## **No Objection:**

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development
  - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- 

## Water Report:

**Referred to IW**

## Foul Drainage Report:

**Referred to IW**

Signed: \_\_\_\_\_  
Padraig Slye GE.

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE.

Date: \_\_\_\_\_