

Water Services Planning Report

Register Reference: SD22B/0097
Development: Single storey front extension to an existing dwelling; and replacement for the windows at the front facade; together with all associated site works
Location: 24, Meadowview Grove, Doddsborough, Lucan, Co. Dublin, K78 W8H4
Applicant: Olan and Carmel O'Callaghan
App. Type: Permission
Date Received: 03-Mar-2022
Report Date: 7th April 2022

Surface Water Report:

No Objection Subject to:

1.1 The applicant shall include Water Butts as part of additional Sustainable Drainage Systems (SuDS) measures for the proposed development.

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____