<b>Register Reference</b> :	SD22B/0002 AI
Development:	(1) New render insulation finish to external walls; (2)
	Replacement of the existing windows; (3) Extension of the
	roof over first floor bay window to allow new thickness of
	external render insulation: (4) Creation of a window opening
	at the west facade of the building at ground floor; (5)
	Demolition of the existing garage, sheds gables and (6)
	Construction of the new extension to the side (east) rear
	(north), the extensions are part single storey, with flat roofs;
	(7) Internal refurbishment and alterations to the existing
	building; (8) New utilities meters wall, landscaping and
	associated site works.
Location:	St. Kevins, 17, Rathfarnham Park, Rathfarnham, Dublin 14.
Applicant:	William Judge and Aranzazu Lera Anton
App. Type:	Permission
Date Received:	04-Jan-2022
<b>Report Date</b> :	12 <sup>th</sup> April 2022

## **Surface Water Report:**

## No Objection Subject to:

- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

## Flood Risk Report:

Water Report:

Foul Drainage Report:

Signed:

Ronan Toft AE

**No Objection** 

**Referred to IW** 

**Referred to IW** 

## Water Services Planning Report

Endorsed:

Date:

Brian Harkin SEE