

Water Services Planning Report

Register Reference: SD22B/0133
Development: Attic conversion for storage; dormer to the rear with 3 roof windows to the front.
Location: 163, Kimmage Road West, Dublin 12
Applicant: Paul Dalton
App. Type: Permission
Date Received: 30-Mar-2022
Report Date: 25th April 2022

Surface Water Report:

No Objection Subject to:

1.1 The applicant shall include water butts as part of SuDS (Sustainable Drainage Systems) features for the proposed development.

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Not Applicable

Foul Drainage Report:

Not Applicable

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____