



NOTES

VEOLIA SCOPE

DOSING CABIN BOUNDARY

NOTES

- ITEMS FREE ISSUED FOR INSTALLATION ON-SITE BY OTHERS
- 4 AIR CHANGES PER HOUR

TIE-IN POINTS

NAME	SIZE	CONN. TYPE	DESCRIPTION
01	DN10	PN10	OXY SCAVENGER CHEMICAL DOSING TO HOT WELL
02	DN10	PN10	SCALE / SLUDGE INHIBITOR CHEMICAL DOSING TO HOT WELL
03	DN10	PN10	ALKALINITY TREATMENT CHEMICAL DOSING TO HOT WELL
04	DN10	PN10	CONDENSATE TREATMENT CHEMICAL DOSING TO HOT WELL
05	2"	SOCKET WELD	COMMON VENT EXHAUST TO ATMOSPHERE
06	VARIOUS	GLAND	SIGNALS IN & OUT
07	VARIOUS	GLAND	POWER SUPPLY

CHEMICAL DOSING CABIN

0	CONTRACT ISSUE	SR, Z.D	17/12/23
REV	DESCRIPTION	DRN, ENG, APP	DATE

CONTROLLED

THIS DRAWING IS THE PROPERTY OF VEOLIA WATER TECHNOLOGIES. THE DETAILS SHOWN ARE STRICTLY CONFIDENTIAL AND MUST NOT BE DISCLOSED TO ANY THIRD PARTY WHOLLY OR PARTLY WITHOUT THE CONSENT OF VEOLIA WATER TECHNOLOGIES.

VEOLIA

Dakin Road, Celbridge Co. Kildare, Ireland Tel: 01 630 3333, Fax: 01 630 3344 www.veoliatechnologies.ie

CLIENT: PFIZER GRANCE CASTLE

CLIENT ADDRESS: CLONDALKIN, Co.DUBLIN

PROJECT: BOILER DOSING CONTAINER

TITLE: Boiler Chemical Dosing Cabin P&ID

DRAWN DATE: 14/12/21	SCALE: N/A	DRAWING NUMBER: 2743-06-001	REV: 0
DRAWN BY: S.R. ENGINEER	Z.D.	PROJECT No: - FLEWMC 2743-06-001	
CONTRACT No: 2743			SHEET 1 of 1