Irish Water's Statutory	South Dublin	Planning Authority
Response to		



Uisce Éireann Bosca OP 6000 Baile Átha Cliath 1

Irish Water PO Box 6000 Dublin 1 Ireland

T: +353 1 89 25000 F: +353 1 89 25001 www.water.ie

Date Lodged with Planning Authority: 11/02/2022

Development:

Planning Application No.

Two-storey 4 bedroom detached dwelling with vehicular access and 2 off-street, parking spaces and all associated site works at side garden plot.

SD22A/0047

Location:

41, Watermeadow Park, Oldbawn Tallaght, Dublin 24 D24CH7V



IW Recommendation: Further Information Required

IW Observations:

- 1 Water
- 1.1 The applicant has not submitted water supply drawings for the proposed development. The applicant is required to submit a drawing in plan outlining the existing and proposed water supply layout for the development. Maps of the public watermains and Wastewater drainage networks may be obtained, if available, for required locations in by emailing: datarequests@water.ie. All proposals are to comply with the Irish Water Standard Details for Water Infrastructure available at (https://www.water.ie/connections/Water-Standard-Details.pdf)
- Prior to the commencement of development the applicant or developer shall enter into water connection agreement(s) with Irish Water.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul

- 2.1 The applicant has not submitted foul water drainage plans for the proposed development. The applicant is required to submit a drawing showing existing and proposed foul water drainage layouts up to and including the point of connection to the public foul water sewer. The drawing shall include the location of all Aj's, manholes, pipe size, material type and direction of flow.
- Prior to the commencement of development the applicant or developer shall enter into waste water connection agreement(s) with Irish Water.

Reason: In the interest of public health and to ensure adequate water facilities.

Signed on Behalf of Irish Water: Yvonne Harris

Date: 18/03/2022

