

Register Ref:	SD22A/0126
Development:	Modifications to previously granted SD18A/0053 consisting of external and internal alterations to previously granted development of 2 three-storey buildings (linked at first and second floor levels), increase in area to (total of 6077.2sq.m gross floor area (including one basement level of 1,922sq.m gross floor area) accommodating 38 apartments, including alterations proposed to the previously permitted unit mix, resulting in an overall increase of 6 units in total, i.e. from 2 one-bed; 28 two-bed; 2 three-bed (32 units) to now provide 6 Studio; 9 onebed; 23 two-bed (38 units); no additional floor is proposed, building remains at 3 storeys in height. Increase in the number of car parking spaces from 40 to 44 at basement level (no change to parking on Loreto Terrace). No change is proposed to SuDS, dainage, landscaping or site development works as granted under Reg. Ref. SD18A/0053.
Location:	Junction of Grange Road, Nutgrove Avenue, and Loreto Terrace Rathfarnham.
Applicant:	First Step Homes Ltd.
Application Type:	Permission
Planning Officer:	

Development Summary

The application is for the alteration of previously granted application which results in an increase of 6 units in total. Noise pollution and air pollution restrictions will be necessary for the construction phase.

The above proposal **is acceptable** to the Environmental Health Department – subject to the following condition(s):

Construction Phase

Noise

1. To control, limit and prevent the generation of Environmental Noise Pollution from occurring the Environmental Health Department of South Dublin County Council, hereby informs you that :

The use of machinery, plant, or equipment (which includes pneumatic drills, generators and the movement on and off the site of construction vehicles) is NOT PERMITTED outside the following hours

- Before 07.00 hours on weekdays, Monday to Friday
- Before 09.00 hours on Saturdays.
- After 19.00 hours on weekdays, Monday to Friday.

- After 13.00 hours on Saturdays.
- Not permitted at any time on Sundays, Bank Holidays or Public Holidays.

Reason: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

Air Quality

During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

Reason: To contain dust arising from construction / demolition in the interests of public health and to prevent nuisance being caused to occupiers of buildings in the vicinity.

Gillian Wynne
Senior Environmental Health Officer
10th May 2022

David OBrien
Principal Environmental Health Officer
10th May 2022

