

Water Services Planning Report

Register Reference: SD22B/0140
Development: First floor extension to side of existing dwelling with new roof light to side of hipped roof.
Location: 17 Wainsfort Grove, Terenure, Dublin 6W.
Applicant: Simon King and Helen MacDonagh
App. Type: Permission
Date Received: 07-Apr-2022
Report Date: 5th May 2022

Surface Water Report:

No Objection Subject to:

- 1.1 Include water butts as part of SuDS (Sustainable Drainage Systems) features for the proposed development.

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____