

# Water Services Planning Report

**Register Reference No.:** SD22A/0109  
**Development:** Retention of the generator compound (391sq.m) consisting of three generators along with three transformers and ancillary 3 diesel tanks and perimeter treatment on a permanent basis on the southern perimeter of the site with Orchard Avenue; The development also consists of the retention of 3 signs (10.94sq.m) as follows: retention of 1 sign (0.57sq.m) on plinth at the corner of Bianconi Avenue and the N82/Citywest Road; retention of 1 sign (4.58sq.m) on the eastern elevation of Block D facing the N82/Citywest Road and retention of 1 sign (5.79sq.m) on the northern elevation of Block M facing Bianconi Avenue. The development will include retention of all revisions to the permitted landscaping and site development works required.

**Location:** Bianconi Avenue, Citywest Business Campus, Saggart, Co. Dublin

**Report Date :** 18<sup>th</sup> May 2022

---

## Surface Water Report:

## **Further Information Required:**

1.1 Submit a drawing showing the surface water layout of proposed development both before and after development was completed. Show what attenuation is proposed and what surface water attenuation is required.

1.2 Submit a drawing showing what SuDS (Sustainable Drainage Systems) are proposed for the development.

Examples of SuDS include but not limited to:

- Permeable Paving
- Grasscrete
- Green Roofs, Blue Roofs
- Water Butts
- Rain Gardens
- Planter boxes with overflow connection to the public surface water sewer.
- Swales

## **Flood Risk**

## **No Objection:**

- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

---

## Water Report:

## **Referred to IW**

**Water Services Planning Report**

**Foul Drainage Report:**

**Referred to IW**

Signed: \_\_\_\_\_  
Padraig Slye GE.

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE.

Date: \_\_\_\_\_