

Water Services Planning Report

Register Reference: SD22B/0148
Development: Extensions and alterations to existing house to include removal of garage to side; a ground floor flat roof extension to the rear; ground & first floor pitched roof extension to the side; new sloped roof over porch area to front and all associated site works.
Location: 62, Butterfield Avenue, Dublin 14
Applicant: Lee Watson & Aoife Gallagher-Watson
App. Type: Permission
Date Received: 12-Apr-2022
Report Date: 12th May 2022

Surface Water Report:

Further Information Required:

1.1 There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.

1.2 The applicant is required to submit a revised drawing showing plan and cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:

- i) At least 5m from any building, public sewer, road boundary or structure.
- ii) Generally, not within 3m of the boundary of the adjoining property.
- iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- v) Soakaways must include an overflow connection to the surface water drainage network.

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Services Planning Report

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____