


**Date:** 20-May-2022  
**Register Reference:** SDZ22A/0005  
**Development:** Phase Three of the Adamstown District Centre and consists of 37,402sq.m (gross floor area including car parking and storage) of residential development to be constructed in 3 blocks ranging in height from 2 to 9 storeys; There is a total of 436 apartments, comprising 9 studio apartments, 204 one bedroom apartments, 213 two bedroom apartments and 10 three bedroom apartment; An ancillary resident's pavilion building (2 storey) is linked to Block D, ancillary resident's amenity rooms and facilities are also provided at ground floor level of Block A; All apartments are provided with private open space in the form of balconies or gardens; The proposed block description is as follows: Block A (c. 11,821sq.m gross floor area): 4 - 5 storeys in height, with a total of 143 apartments (70 one bedroom apartments, 67 two bedroom 4 person apartments and Gno. 3-bedroom apartments); A resident's only podium level, courtyard is provided within Block A; Ancillary plant, storage, waste, and internal bicycle parking rooms provided at ground floor level; Block C (c. 9,680sq.m gross floor area): 4 - 9 storeys in height, with a total of 124 apartments {60 one bedroom apartments, 5 two bedroom 3 person apartments, 55 two bedroom 4 person apartments and 4 three bedroom apartments). Communal open space is provided within 2 parcels of land to the east of Block C between Block C and Block D. Ancillary plant, waste and internal bicycle parking rooms provided at ground floor level; Block D (c.12,757sq.m gross floor area): 2 - 5 storeys in height, together with linked ancillary resident's pavilion building (2 storey). Block D comprises a total of 169 apartments (9 studio apartments, 74 one bedroom apartments, 11 two bedroom 3 person apartments, and 75 two bedroom 4 person apartments); Communal open space is provided within 2 parcels of land within Block D; Ancillary plant, amenity rooms and internal bicycle parking rooms provided at ground floor level. Ancillary plant, waste and internal bicycle parking rooms provided at ground floor level; on lands generally bounded by Adamstown Avenue to the north, to the east by undeveloped lands which benefit from planning permission Reg. Ref. SDZ20A/0008 (as amended by SDZ20A/0016, SDZ20A/0018 and SDZ21A/0017), to the south by Station Road, the railway line and train station and to the west by the railway overpass and its approach road, known locally as the farmer's bridge.


**Location:** In the townland of Gollierstown, Adamstown, Lucan, Co. Dublin  
**Applicant:** Quintain Developments Ireland Limited  
**App. Type:** SDZ Application  
**Planning Officer:** SARAH WATSON  
**Date Received:** 14-Apr-2022  
**Decision Due Date:** 08-Jun-2022

The proposal is **acceptable** to Environmental Health subject to the following conditions set out below:

1. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.
2. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
3. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.
4. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.
5. The applicant shall put in place a pest control contract for the site for the duration of the construction works.
6. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A).
7. Any connections to the main sewer must be connected so as not to give rise to a public health nuisance.
8. Signage or lighting to be used on site during both construction and the on-going operation of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.
9. Clearly audible or impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.



Mark Whelan  
Environmental Health Officer



Charlene Kiely  
Senior Environmental Health Officer