


Date: 20-May-2022
Register Reference: SDZ22A/0006
Development: Construction of 352 residential units (terraced, semi-detached and detached) comprising 253 two storey houses (15 two bed units and 238 three bed units ranging in size from c. 86sq.m to c. 118sq.m) and 99 three storey houses (18 three bed units and 81 four bed units and ranging in size from c. 147sq.m to c. 189sq.m); The total gross floor area of the development is c. 43,272sq.m; The development will also comprise the provision of 2 vehicular accesses from Adamstown Boulevard, 1 vehicular access from Adamstown Drive (L1030), 2 vehicular accesses from Adamstown Park Road and 2 vehicular accesses from Tandy's Lane; vehicular connections will also be provided to permitted roads in Tandy's Lane Phase 1; internal routes; 535 car parking spaces including on-curtilage and off-curtilage spaces; bicycle parking; bin storage; plant; ESB Substations; boundary treatments; lighting; hard and soft landscaping; and all other associated site works; on 2 No. sites separated by the permitted Tandy's Lane Phase 1 Development (SDCC Reg. Ref. SDZ19A/0011) with a total site area of c. 10.24 hectares at Tandy's Lane, in the townlands of Doddsborough and Finnstown, Adamstown, Lucan, Co. Dublin. The western site (8.06 hectares) is generally bounded to the west by Adamstown Boulevard, to the north by Adamstown Drive (L1030), to the east by the Tandy's Lane Phase 1 Development which is currently under construction (SDCC Reg. Ref. SDZ19A/0011) and undeveloped lands, and to the south by Tandy's Lane which links Adamstown Boulevard with Adamstown Park Road. The eastern site (2.18 hectares) is generally bounded to the west / north-west by the permitted Tandy's Lane Phase 1 Development, to the east by Adamstown Park Road and to the south by Tandy's Lane; This application is being made in accordance with the Adamstown Planning Scheme 20141 (as amended) and relates to a proposed development within the Adamstown Strategic Development Zone Planning Scheme. The lands are located within the Tandy's Lane Village Development Area.


Location: Tandy's Lane, In the townlands of Doddsborough and Finnstown, Adamstown, Lucan, Co. Dublin
Applicant: Quintain Developments Ireland Limited
App. Type: SDZ Application
Planning Officer: CAITLIN O'SHEA
Date Received: 13-Apr-2022
Decision Due Date: 07-Jun-2022

The proposal is **acceptable** to Environmental Health subject to the following conditions set out below:

1. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.
2. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
3. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.
4. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.
5. The applicant shall put in place a pest control contract for the site for the duration of the construction works.
6. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A).
7. Any connections to the main sewer must be connected so as not to give rise to a public health nuisance.
8. Signage or lighting to be used on site during both construction and the on-going operation of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.
9. Clearly audible or impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.



Mark Whelan
Environmental Health Officer



Charlene Kiely
Senior Environmental Health Officer

