

- LIST OF IRISH WATER STANDARD DETAILS BROUGHT INTO THE CONTRACT
- STD-W-04 GENERAL PIPE CONNECTIONS (SHEET 1 OF 7)
 - STD-W-05 GENERAL PIPE CONNECTIONS (SHEET 2 OF 7)
 - STD-W-06 GENERAL PIPE CONNECTIONS (SHEET 3 OF 7)
 - STD-W-07 GENERAL PIPE CONNECTIONS (SHEET 4 OF 7)
 - STD-W-08 GENERAL PIPE CONNECTIONS (SHEET 5 OF 7)
 - STD-W-09 GENERAL PIPE CONNECTIONS (SHEET 6 OF 7)
 - STD-W-10 GENERAL PIPE CONNECTIONS (SHEET 7 OF 7)
 - STD-W-11 TYPICAL SERVICE LAYOUT INCLUDING SEPARATION DISTANCES TO WASTEWATER
 - STD-W-12 RESTRICTIONS ON TREES / SHRUBS PLANTING ADJACENT TO WASTEWATER
 - STD-W-13 TRENCH BACKFILL & BEDDING
 - STD-W-14 SLUICE VALVE FOR DUCTILE IRON (D.I.) PIPE (330MM DIA) (SHEET 1 OF 2)
 - STD-W-15 SLUICE VALVE FOR POLYETHYLENE (P.E.) PIPE (330MM DIA) (SHEET 2 OF 2)
 - STD-W-16 ON-LINE HYDRANT FOR DUCTILE IRON (D.I.) PIPE (SHEET 1 OF 4)
 - STD-W-17 OFF-LINE HYDRANT FOR DUCTILE IRON (D.I.) PIPE (SHEET 2 OF 4)
 - STD-W-18 ON-LINE HYDRANT FOR POLYETHYLENE (P.E.) PIPE (SHEET 3 OF 4)
 - STD-W-19 OFF-LINE HYDRANT FOR POLYETHYLENE (P.E.) PIPE (SHEET 4 OF 4)
 - STD-W-20 ON-LINE AIR VALVE FOR DUCTILE IRON (D.I.) PIPE (SHEET 1 OF 4)
 - STD-W-21 OFF-LINE AIR VALVE FOR DUCTILE IRON (D.I.) PIPE (SHEET 2 OF 4)
 - STD-W-22 ON-LINE AIR VALVE FOR POLYETHYLENE (P.E.) PIPE (SHEET 3 OF 4)
 - STD-W-23 OFF-LINE AIR VALVE FOR POLYETHYLENE (P.E.) PIPE (SHEET 4 OF 4)
 - STD-W-24 PRESSURE REDUCING / SUSTAINING VALVE (R/P/S/SV) CHAMBER
 - STD-W-25 METER CHAMBER (330MM DIA)
 - STD-W-26 METER CHAMBER (450MM DIA)
 - STD-W-27 MARKER POSTS / PLATES
 - STD-W-28 WATER MAIN TRUSS & SUPPORT BLOCKS
 - STD-W-29 SOAK CHAMBER & HEAD WALL ARRANGEMENTS
 - STD-W-30 WASTEWATER HYDRANT
 - STD-W-31 TYPICAL DITCH / STREAM CROSSING FOR WATER MAIN

- LIST OF IRISH WATER WASTEWATER STANDARD DETAILS BROUGHT INTO THE CONTRACT
- STD-WW-02 TYPICAL LAYOUT FOR SEWER WITHIN NEW DEVELOPMENT
 - STD-WW-03 DRAIN AND SERVICE CONNECTION PIPEWORK
 - STD-WW-04 TYPICAL SERVICE/SEWER PIPE CONNECTION
 - STD-WW-05 TYPICAL SERVICE LAYOUT INCLUDING SEPARATION DISTANCES
 - STD-WW-06 RESTRICTIONS ON TREES/SHRUBS PLANTING ADJACENT TO SEWERS
 - STD-WW-07 TRENCH BACKFILL & BEDDING
 - STD-WW-08 CONCRETE BED, MANHOLE & SURROUND TO WASTEWATER PIPES
 - STD-WW-09 BLOCKWORK MANHOLE (450mm)
 - STD-WW-10 PRE-CAST CONCRETE MANHOLE
 - STD-WW-11 IN-SITU CONCRETE MANHOLE
 - STD-WW-12 BACKDROP MANHOLES
 - STD-WW-13 PRIVATE USE INSPECTION CHAMBER

- NOTES
- ALL DRAWINGS TO BE CHECKED BY CONTRACTOR ON SITE AND ENGINEER INFORMED OF DISCREPANCIES BEFORE WORK COMMENCES
 - ALL LEVELS ARE IN METRES AND ARE RELATED TO ORDNANCE DATUM
 - ALL DIMENSIONS TO BE IN MILLIMETERS UNLESS NOTED OTHERWISE
 - CONTRACTOR SHALL SATISFY HIMSELF AS TO THE ACCURACY OF PAVEMENT LEVELS ON SITE PRIOR TO COMMENCEMENT OF WORKS ON SITE
 - ALL SURFACE WATER DRAINAGE WORKS TO BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE LOCAL AUTHORITY'S CODE OF PRACTICE FOR DRAINAGE AND THE CDDSS
 - ALL SURFACE WATER SEWERS TO BE CLASS H CONCRETE TO EN1916 & IS 6 2004
 - ALL FOUL DRAINAGE WORKS TO BE IN ACCORDANCE WITH IRISH WATER'S CODE OF PRACTICE FOR WASTEWATER SUPPLY AND WASTEWATER INFRASTRUCTURE STANDARD DETAILS
 - FOUL SEWERS TO BE THERMOPLASTIC STRUCTURED WALL PIPES (COMPLYING WITH THE PROVISION OF IS EN 13476 AND MS 4-35-D1 2000) AND COMPLY WITH THE REQUIREMENTS OF THE IRISH WATER CODE OF PRACTICE
 - WATERMAIN INSTALLATION AND ALL WATER SUPPLY WORKS TO BE IN ACCORDANCE WITH THE REQUIREMENTS OF IRISH WATER'S CODE OF PRACTICE FOR WATER SUPPLY AND WATER INFRASTRUCTURE STANDARD DETAILS
 - WATERMANS TO BE TYPE HPPE, PE-100, SDR-17 RATED AND SHALL CONFORM TO IS EN 12201 (PART 1, PART 2 & PART 3)
 - WATERMAIN SERVICE CONNECTION PIPES TO BE HDPE (PE-80) MATERIAL WITH SDR-17 RATING
 - ANCHOR BLOCKS TO BE POSITIONED AT DEAD ENDS, TEES, BENDS AND AT EACH SIDE OF HYDRANTS AND VALVES IN ACCORDANCE WITH THE REQUIREMENTS OF IRISH WATER STANDARD DETAIL STD-W-28 (WATER MAIN THRUST AND SUPPORT BLOCKS)
 - HYDRANT OUTLET TO BE 200mm BELOW GROUND LEVEL UNLESS REQUESTED OTHERWISE
 - WHERE COVER TO PIPE IS LESS THAN 900mm IN GREEN AREAS AND 1200mm IN TRAFFICKED AREAS, ENCASE PIPE IN NEW 150mm CONCRETE WITH MOVEMENT JOINTS

- LEGEND
- Proposed Surface Water Manhole
 - Proposed Surface Water Sewer
 - Proposed Surface Water Downpipe with Roofing Eye
 - Proposed Linear Surface Drain (ACO GSA)
 - Proposed Linear Surface Drain at Basement Slab Level (ACO GSA)
 - Existing Surface Water Sewer
 - Site Boundary
 - Proposed Building
 - Proposed Footpath
 - Proposed Roadway
 - Proposed Permeable Paving
 - Extent of Basement
 - Proposed Green Roof
 - Proposed Attenuation Facility

| Rev | Date | Description | By | Chk |
|-----|----------|---------------------|----|-----|
| P1 | 28/04/22 | CH RESPONSE | SM | SJ |
| P | 15/10/21 | PLANNING SUBMISSION | SM | SJ |

PLANNING

gdcl
CONSULTING ENGINEERS

Scope House, Perrystown, Dublin D12 K8PP
75 Shelton Street, Covent Garden, London WC2H 9JQ
www.gdalconsulting.com

PROJECT
U-Store-It, Liffey Valley

CLIENT
Oceanglade Ltd

DRAWING TITLE
Proposed Surface Water Layout

| | | |
|------------------|----------------------|--------------|
| dm. by: PTC | date: Dec '19 | scale: 1:250 |
| drawing size: A1 | chk: SJ | app: GD |
| job no: P2005 | drw. no: P2005-C-204 | rev: P1 |

NOT FOR CONSTRUCTION

