

Telephone: 01 4149000

Fax: 01 4149104

Email: [planningdept@sdblincoco.ie](mailto:planningdept@sdblincoco.ie)

TOBIN Consulting Engineers  
Block 10-4  
Blanchardstown Corporate Park  
Dublin  
D15 X98N

Date: 26-May-2022

**PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING  
REGULATIONS THEREUNDER**

Register Reference: SD21A/0167

**Development:** Construction of a gas fired power plant with an electrical output of up to 125MW with associated balance of plant, equipment and buildings including: an Engine Hall building with a height of 18.9m, comprising 6 gas engines and ancillary infrastructure; an Electrical Annex Building with a height of 18.7m; a Workshop building with a height of 5.1m; a Tank Farm building with a height of 5.68m; a Security hut with a height of 3.27m; an Exhaust Stack with a height of 31.8m; a Gas AGI including a kiosk with height of 3.3m; Radiator Coolers with a height of 8.46m; 2 electrical transformers with a height of 4.98m; Tanks including 2 x Diesel Oil Storage Tanks (volume of 2500m<sup>3</sup> combined); SCR Urea Tank (26m<sup>3</sup>); Lube Oil Storage Tank (26m<sup>3</sup>); Lube Oil Maintenance Tank (26m<sup>3</sup>); Pilot Oil Tank (26m<sup>3</sup>); Fire Water Storage Tank (1000m<sup>3</sup>); Effluent Collecting Tank (26m<sup>3</sup>); Underground Surface Water Attenuation Tank (490m<sup>3</sup>); 2 new access onto the existing private road network with Profile Park; 12 parking spaces, footpaths, landscaping; fencing and all other associated site development plant and equipment and other works including surface water and foul wastewater drainage. An EIAR was submitted with this application.

**Location:** Profile Park, Baldonnel, Dublin 22


**Applicant:** Shane Minehane, Greener Ideas Limited

**Submission Type:** Significant Additional Information

Dear Sir/ Madam,

With reference to the above, I acknowledge receipt of Significant Additional Information received 25-May-2022.

Yours faithfully,

  
for Senior Planner