

# Water Services Planning Report

**Register Reference No.:** SD22A/0127

**Development:** Construction of a single storey (staff room) extension to the front (southeast) of the school (including a rooflight); construction of a single storey classroom extension to the rear (northwest) of the school; All associated elevational changes, internal alterations, site, landscaping and ancillary works.

**Location:** St. Kevin's Girls National School, Treepark Drive, Kilnamanagh, Dublin 24

**Report Date :** 7<sup>th</sup> June 2022

---

## Surface Water Report:

## **Further Information Required:**

**1.1** The applicant has not proposed any SuDS (Sustainable Drainage Systems) features for the proposed development. The applicant is required to submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development.

Examples of SuDS include but not limited to the following:

- Green Roofs
- Grasscrete
- Permeable Paving

## **Flood Risk**

## **No Objection:**

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
  - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- 

## Water Report:

**Referred to IW**

## Foul Drainage Report:

**Referred to IW**

Signed: \_\_\_\_\_  
Adam Adderley-McCabe GE.

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE.

Date: \_\_\_\_\_