



South Dublin County Council
Planning Department
County Hall,
Tallaght
Dublin 24
D24 YNN5

10 June 2022

Re: PLANNING REGISTRATION NO: SD21A/0167

Dear Sir/Madam,

I write with regard to the above planning application by Greener Ideas Limited, for construction of a gas fired power plant with an electrical output of up to 125MW with associated balance of plant, equipment and buildings including; an Engine Hall building with a height of 18.9m.

Located: Profile Park, Baldonnell, Dublin 22.

Following consultations with our Air Corps colleagues at Casement Aerodrome, The Department of Defence would like to make the following observation:

Given the proximity to Casement Aerodrome, operation of cranes should be coordinated with Air Corps Air Traffic Services, no later than 28 days before use, contactable at airspaceandobstacles@defenceforces.ie or 01-4037681

Due to the proximity to Casement Aerodrome, the developer should produce a Wildlife Aviation Impact Assessment and implement adequate bird control measures during the construction phase to mitigate the effects of birds on Air Corps flight operations.

Due to the proximity to Casement Aerodrome, mitigations may be required in relation to the management of wildlife attracted to attenuation ponds or other water features. Should negative effects of bird activity on Irish Air Corps operations arise, the owner must put measures in place to mitigate these effects to an acceptable level.

Due the proximity to Casement Aerodrome, Military Air Traffic Services requests an Aviation Impact Assessment on all potential emissions. The assessment should cover the possible effects of exhaust plumes or any other associated impact on flight operations at Casement Aerodrome.



Please contact me if you have any queries in this regard.

Yours faithfully,

Sent via e-mail

Don Watchorn
Property Management Branch
Department of Defence
Station Road
Newbridge
Co. Kildare W12 AD93
045 452199 don.watchorn@defence.ie