



LEGEND:

- PROPOSED DN110 HDPE WATERMAIN — PR-WM — PR-WM — PR-WM —
- EXISTING WATERMAIN — EX-WM — EX-WM — EX-WM —
- PROPOSED SLUICE VALVE
- PROPOSED WASHOUT HYDRANT
- PROPOSED BULK METER
- PROPOSED FIRE-HYDRANT

NOTES:

1. WATERMAIN "T" JUNCTIONS TO BE IN ACCORDANCE WITH THE STANDARD DETAIL STD-W-05.
2. TYPICAL SERVICE LAYOUT DISTANCES, HORIZONTALLY AND VERTICALLY, TO BE IN ACCORDANCE WITH THE STANDARD DETAIL STD-W-11.
3. TRENCH BACKFILL AND BEDDING TO BE IN ACCORDANCE WITH THE STANDARD DETAIL STD-W-13.
4. WATERMAIN THRUST AND SUPPORT BLOCKS TO BE IN ACCORDANCE WITH THE STANDARD DETAIL STD-W-28.
5. HYDRANTS SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF 3.5.25 OF IRISH WATER CODE OF PRACTICE.
6. DEPTHS OF ALL WATERMANS TO COMPLY WITH REQUIREMENTS OF 3.11 OF IRISH WATER CODE OF PRACTICE.

WATERMAIN TO BE INSTALLED IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE

R46m

SUPPLY TO INTERNAL WATER TANK ROOM AND DOMESTIC METERS FOR no. 25 APARTMENTS

GROUND

PLANNING DRAWING.
 NOT FOR CONSTRUCTION.
 ALL LEVELS GIVEN ARE
 RELATIVE TO ORDNANCE DATUM.
 THIS DRAWING HAS BEEN ISSUED FOR INFORMATION
 PURPOSES ONLY AND MUST NOT BE USED
 FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES

- FOR SETTING OUT REFER TO ARCHITECT'S DRAWINGS.
- THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER ARCHITECTURAL AND ENGINEERING DRAWINGS AND ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
- DO NOT SCALE THIS DRAWING. USE FIGURED DIMENSIONS ONLY.
- NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF O'CONNOR SUTTON CRONIN AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

Rev No.	Date	Revision Note	Drn by	Chkd by
PO1	29.02.22	SUITABLE FOR INFORMATION	EH	MK
PO2	06.05.22	SUITABLE FOR PLANNING	EH	MK
PO3	20.05.22	SUITABLE FOR PLANNING	EH	MK

Rev No.	Date	Revision Note	Drn by	Chkd by



Head Office,
 9 Prussia Street,
 Dublin 7,
 D07 KT57



TEL +353 (0)1 8682000
 e: contactus@ocsc.ie
 w: www.ocsc.ie

Dublin London Belfast Galway Cork Birmingham

Client: MSJA LTD
 Project: PROSPECT HOUSE, STOCKING LANE
 RATHFARNHAM
 Title: PROPOSED WATERMAIN LAYOUT

Code	Originator	Zone	Level	Type	Role	Number	Status	Revision
S627	OCSC	XX	XX	DR	C	0550	S4	P03

Date: APR'22 Scale: 1:200 @ A1 Drn by: EH Chkd by: MK Aprvd by: MOR