

# Water Services Planning Report

**Register Reference No.:** SD22A/0152  
**Development:** Shopfront alterations which comprise of fitting of new branded signage (after removal of existing signage/ or over existing signage) onto existing shopfront, replacement of existing ATM with new ATM (location retained); minor internal alterations to existing front banking hall to consist of new internal SSBM/ ATMs within new room.

**Location:** Ulster Bank, The Mall, Lower Main Street, Edmondsbury, Lucan, Co. Dublin

**Report Date :** 30-June-2022

---

## Surface Water Report:

**No objection subject to:**

### **Flood Risk**

**No Objection**

All floor levels shall be a minimum of 500mm above the highest know flood level for the site.

- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- 

## Water Report:

**Not Applicable**

## Foul Drainage Report:

**Not Applicable**

Signed: \_\_\_\_\_  
Brian Harkin SEE.

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_

Date: \_\_\_\_\_