Water Services Planning Report

Register Reference No.: SD22A/0154

Development: Amendment to existing planning permission: change of

style of the new house already granted under SD21A/0233 in the side garden to have a more traditional design and

layout.

Location: 1, Kilakee Park, Dublin 24, D24 W9T2

Report Date: 01-July-2022

Surface Water Report:

Further Information required:

- 1.1 There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 Soakaway Design.
- 1.2 The applicant is required to submit a revised drawing showing plan and cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
- i) At least 5m from any building, public sewer, road boundary or structure.
- ii) Generally, not within 3m of the boundary of the adjoining property.
- iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- v) Soakaways must include an overflow connection to the surface water drainage network.
- **1.3** Include water butts in proposed development as part of SuDS (Sustainable Drainage System).

Flood Risk

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Services Planning Report

Water Report:			Referred to IW
Foul Drain	age Report:		Referred to IW
Signed:	Brian Harkin SEE.	Date:	
Endorsed:		Date:	