

**Irish Water's Statutory  
Response to**

**South Dublin**

**Planning Authority**



**Uisce Éireann**  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

**Irish Water**  
PO Box 6000  
Dublin 1  
Ireland

**T: +353 1 89 25000**  
**F: +353 1 89 25001**  
**[www.water.ie](http://www.water.ie)**

**Planning Application No.**

SD22A/0093 AI

**Date Lodged with Planning Authority:**

23/06/2022

**Development:**

Amendments to the development permitted under Reg. Ref. SD20A/0309 comprising: alterations to permitted ICT Facility buildings 2 and 3, to include internal reconfiguration of the ICT equipment halls, associated electrical and mechanical plant rooms, loading bays, maintenance and storage space, office administration areas, and reconfiguration of screened plant; alterations to the external facades of permitted ICT Facility buildings 2 and 3 to include modification and reconfiguration of fenestration, louvers, loading bays, and access doors, along with an increase in height of 1.2 metres to main parapet level and reduction in the height of rooftop plant to not exceed the parapet height of the buildings, along with the omission of previously permitted flues and exhaust ducts at roof level; omission of emergency generators and associated flues from permitted ICT Facility buildings 2 and 3; The proposed amendments to ICT Facility buildings 2 and 3 result in an increase in their gross floor area (GFA) of 2,511sq.m for each building, resulting in an overall increase in the GFA of the two buildings of 5,022sq.m; Alterations to the water storage tanks serving the permitted ICT Facility buildings, including total increase of 268 sq.m GFA to the permitted pumphouses and a reduction in the scale of the associated water storage tanks. All associated and ancillary works; The application site is subject to an EPA Industrial Emissions Licence relating to the Energy Centre permitted on site (under Reg. Ref.: SD18A/0068 as amended by Reg. Ref.: SD19A/0185).

**Location :**

3-4, Crag Avenue, Clondalkin Industrial Estate, Clondalkin, Dublin 22

**IW Recommendation:** **No Objection**

**IW Observations:**

1 Water

1.1 Prior to the commencement of development the applicant or developer shall enter into a water

connection agreement(s) with Irish Water.

- All development shall be carried out in compliance with Irish Water Standards codes and practices.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul

2.1 Prior to the commencement of development the applicant or developer shall enter into a wastewater

connection agreement(s) with Irish Water.

- All development shall be carried out in compliance with Irish Water Standards codes and practices.

Reason: In the interest of public health and to ensure adequate water facilities.

Signed on Behalf of Irish Water: Yvonne Harris

Date: 19/07/2022

