

Water Services Planning Report

Register Reference No.: *SD22A/0060 AI*
Development: Change of use of 464sq.m of warehouse mezzanine storage, approved under planning reference SD18A/0031, to office use, as well as associated and ancillary internal works, elevational changes and external ground works to facilitate this new use.
Location: Cloverhill Industrial Estate, Cloverhill Road, Dublin 22
Report Date : 21-July-2022

Surface Water Report:

No objection subject to:

Flood Risk

No objection subject to:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage systems within the site, both in respect of installation and use.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works which can be viewed /downloaded from the South Dublin County Council website at the following link <http://www.sdcc.ie/sites/default/files/publications/greater-dublin-regional-code-of-practice-for-drainage-works.pdf>
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
 Brian Harkin

Date: _____

Endorsed: _____

Date: _____