

Water Services Planning Report

Register Reference No.: SD22A/0278
Development: Proposed change of use of House 1, an existing residential building, for use as office and meeting facilities ancillary to the services provided on the site and the installation of a new ramp to main entrance at house 1 on an overall site within the curtilage of Kimmage Manor, a protected structure (RPS Ref No: 185).

Location: House 1, Kimmage Manor, Whitehall Road, Kimmage, Dublin 12

Report Date : 26-July-2022

Surface Water Report:

No objection:

Flood Risk

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Adam Adderley-McCabe GE

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____