Water Services Planning Report

Register Reference No.: Development:	SD22A/0292 Construction of additional floor area of 192.43sqm to existing warehouse and office building of 1658.44sqm, alterations to layout of 152.11sqm of existing warehouse and alterations to existing parking layout to accommodate disabled parking. New first floor of 169.75sqm internally in existing warehouse, internal alterations at ground level, 2 storey extension to southern elevation of existing warehouse to accommodate new entrance lobby and all associated site works.
Location:	Healy Chemicals Ireland Ltd, HCL House, Second Avenue, Cookstown Industrial Estate, Tallaght, Dublin 24
Report Date:	5-Aug-2022
Surface Water Report: Further Information Required:	
 1.1 Submit a report showing surface water attenuation calculations for proposed development. Show what surface water attenuation is required in m³ and show also what surface water attenuation is provided in m³. Surface water attenuation shall be provided by means of SuDS (Sustainable Drainage Systems). 1.2 Submit a drawing showing what SuDS care proposed for the development. Examples of SuDS can be found in SuDS Guide on South Dublin County Council Web Site at sdcc-suds-explanatory-design-and-evaluation-guide.pdf 	
Flood Risk	No Objection
All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.	
Water Report:	Referred to IW
Foul Drainage Report	Referred to IW
Signed: Brian Hark	Date:
Endorsed: Juliene He	Date: