

Water Services Planning Report

43

Register Reference No.: *SD22A/0031 AI*

Development: 1) Demolition of existing single storey garage and rear single storey extension; (2) construction of a new two storey, semi-detached dwelling house with an attic conversion and widening existing vehicular access to serve existing dwelling house at 29 Ballyboden Road, Rathfarnham, Dublin 14.

Location: 29, Ballyboden Road, Rathfarnham, Dublin 14

Report Date : 25th Aug 2022

Surface Water Report:

No Objection Subject To:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE

Date: _____

Endorsed: _____
Juliene Helbert

Date: _____