

# Water Services Planning Report

**Register Reference No.:** SD22A/0306  
**Development:** Change of use of 4sq.m of warehouse floor area to Staff Facilities floor area at the ground floor plan and minor adjustments to the internal Staff Facilities layout to accommodate Part M requirements (no associated area alterations); elevational changes, addition of 2 level access doors to the building's northern elevation and 2 level access doors to the building's eastern elevation; addition of 1 fire escape door from the ancillary office block to the building's eastern elevation; associated site plan & drainage adjustments.

**Location:** Block R, Jordanstown Road, Aerodrome Buisness Park, Rathcoole, Co. Dublin

**Report Date :** 24<sup>th</sup> Aug 2022

## Surface Water Report:

**No objection subject to:**

1.1 The applicant has not proposed any SuDS (Sustainable Drainage Systems) features for the proposed development. The applicant is required to submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development. Examples include but are not limited to:

- Rain Gardens , Planter boxes with overflow connection to the public surface water sewer.
- Swale
- Permeable Paving
- Grasscrete

## **Flood Risk**

**No Objection**

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

---

## Water Report:

**Referred to IW**

## Foul Drainage Report:

**Referred to IW**

Signed: \_\_\_\_\_  
Adam Adderley-McCabe GE

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE

Date: \_\_\_\_\_