



GENERAL NOTES:

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS, ANY DISCREPANCIES, ERRORS OR OMISSIONS TO BE BROUGHT TO THE ATTENTION OF THE DESIGNER.
2. DO NOT SCALE. ALL MEASUREMENTS AND COORDINATES TO BE CHECKED ON SITE.
3. FOR THE OUTDOOR LIGHTING REPORT REFER TO DOCUMENT T21025-TL-ZZ-XX-RP-Y-0001-P05 -OUTDOOR LIGHTING REPORT.

LEGEND:

Grid 1
Results - Horizontal Illuminance (lux)

Eav= 5.51
Emin= 1.00
Emax= 14.37
Emin/Emax= 0.07
Emin/Eav= 0.18
Emax/Eav= 2.61

Luminaire Data
Luminaire A
TRSA-02-SCP-4L30819W
Lamp 8Du4L19W3K
MF 0.90

Luminaire B
TRSA-02-150-4L30819W
Lamp 8Du4L19W3K
MF 0.90

- Key**
- Luminaire A Column
 - Luminaire B Column
 - Beam Aiming Target
 - Photometric Centre

Rev	Date	Description	Drwn	App
P05	2022-07-21	ISSUED FOR PLANNING	RM	GM
P04	2021-09-13	ISSUED FOR PLANNING	JM	GM
P03	2021-09-09	ISSUED FOR PLANNING	JM	GM
P02	2021-09-06	ISSUED FOR PLANNING	RM	GM
P01	2021-08-04	ISSUED FOR PLANNING	RM	GM

Project Number	Drawing Number	Revision
T21025	TL-ZZ-XX-DR-Y-0001	P05

Designer	Date	Approved	Date	Scale
RM	2022-07-21	GM	2022-07-21	1:500

Project

**PROPOSED
SITE LIGHTING LAYOUT**

Drawing

**FS-169-RATHFARNHAM
RESIDENTIAL DEVELOPMENT**



TASKLED,
6 EDEN GATE CENTRE,
DELGANY,
CO. WICKLOW,
IRELAND, A63 EK44
PHONE +353 (0) 1287 0528
www.taskled.ie