An Roinn Cosanta Department of Defence



South Dublin County Council Planning Department County Hall, Tallaght Dublin 24 D24 YNN5

06 September 2022

Re: PLANNING REGISTRATION NO: SD22A/0333

Dear Sir/Madam,

I write with regard to the above planning application by EdgeConneX Ireland Limited for the construction of 2 adjoined single storey data centres, with 24 standby diesel generators with associated flues each 25m high.

Located: The Townland of Ballymakaily, West of Newcastle Road (R120), Lucan, Co. Dublin.

Following consultations with our Air Corps colleagues at Casement Aerodrome, The Department of Defence would like to make the following observations:

- Given the proximity to Casement Aerodrome, operation of cranes should be coordinated with Air Corps Air Traffic Services, no later than 28 days before use, contactable at airspaceandobstacles@defenceforces.ie or 01-4037681
- Due to the proximity to Casement Aerodrome, the developer should produce a
 Wildlife Aviation Impact Assessment and implement adequate bird control
 measures during the construction phase to mitigate the effects of birds on Air
 Corps flight operations.
- Due to the proximity to Casement Aerodrome, mitigations may be required in relation to the management of wildlife attracted to attenuation ponds or other water features. Should negative effects of bird activity on Irish Air Corps operations arise, the owner must put measures in place to mitigate these effects to an acceptable level.
- Due the proximity to Casement Aerodrome, Military Air Traffic Services requests an Aviation Impact Assessment on all potential emissions. The assessment should cover the possible effects of exhaust plumes or any other associated impact on flight operations at Casement Aerodrome.



Please contact me if you have any queries in this regard.

Yours faithfully,

Sent via e-mail

Don Watchorn
Property Management Branch
Department of Defence
Station Road
Newbridge
Co. Kildare W12 AD93

045 492199 don.watchorn@defence.ie