



Project

STONEYHILL

Client



Consultant

AECOM
Adelphi Plaza
George's Street Upper
Dún Laoghaire, Co. Dublin
A96 T927
Ireland
Tel +353 (0) 1 696 6200
www.aecom.com

Notes

- 1. THE CONTRACTOR SHALL LIASE WITH ESB NETWORKS AND ALL RELEVANT UTILITY COMPANIES IN RELATION TO ALL REQUIRED RELOCATION OF PLANT AND INCLUDE FOR ALL REQUIRED DIVERSIONS AND DUCTING AS REQUIRED.
- 2. ALL DUCTS TO BE WATERTIGHT AND SEALED WHERE ENTERING THE BUILDING. DUCTS SHALL BE LAID IN FULLY LINBROKEN LENGHTS
- FULLY UNBROKEN LENGHTS.

 3. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ARCHITECTS SITE DRAWINGS, INCLUDING LANDSCAPE
- DRAWINGS.

 4. DUCTS BETWEEN LIGHTING STANDARDS SHALL BE INSTALLED ON ONE SIDE OF THE LANDSCAPE AREA, SO AS NOT TO
- HINDER TREE'S AND SHRUB PLANTING.

 5. EXCAVATION WORK WITHIN THE VICINITY OF GAS PIPELINES ARE TO BE CARRIED OUT IN ACCORDANCE WITH THE HEALTH AND SAFETY AUTHORITY CODE OF PRACTICE FOR AVOIDING DANGER FROM UNDERGROUND SERVICES.
- EACH LENGTH OF DUCT SHALL BE STAMPED WITH THE WORDS "PUBLIC LIGHTING" OR ALTERNATIVELY "STREET LIGHTING", IN 18MM BLACK LETTERING AT 0 DEGREES, AT ONE METER INTERVALS. DUCT SHALL BE LAID WITH THIS LEGEND FACING UPWARDS.
 A MINIMUM DEPTH OF 450MM COVER IS
- REQUIRED IN URBAN PATHWAYS & A MINIMUM OF 600MM COVER IS REQUIRED FOR GRASS MARGINS, PEDESTRIAN WAYS, LANEWAYS & GATEWAY ENTRANCES & A MINIMUM DEPTH OF 750MM IS REQUIRED AT ROAD CROSSINGS OR IN CARRIAGEWAYS.
- 8. LUMINAIRE TO BE COWLED TO BE DIRECTED AWAY FROM VEGETATED AREAS.

Issue/Revision

	0 1 2	
	2	
P01	20220809	Issued for Planning
Rev	Date	Description

Key Plan

Purpose Of Issue

FOR PLANNING

Project Number

60659192 **Sheet Title**

SITE ILLUMINATION LEVELS PHASE 1 SUBMISSION

Sheet Number

STNH-ACM-ZZ-00-DR-EL-021001

Scale: 1:500 @ A1

Rev: P01