Water Services Planning Report

Register Reference No.: SD22A/0295 AI

Development: Two storey four bedroom detached house to side of 29

Ballyroan Heights Rathfarnham Dublin 16

Location: 29 Ballyroan Heights, Rathfarnham, Dublin 16

Report Date: 15th September 2022

Surface Water Report:

Further Information required:

- **1.1.** Submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development.
- **1.2.** The applicant shall include SuDS (Sustainable urban Drainage Systems) features for the proposed development such as but not limited to the following:
 - Soakaway
 - Rain Gardens, Planter boxes with overflow connection to the public surface water sewer.
 - Permeable Paving
 - Grasscrete
- **1.3.** If a soakaway is proposed, the applicant is required to submit a report showing percolation tests results. The report shall include the following details:
 - i) Which individual had carried out the site test.
 - ii) When the test was carried out
 - iii) Which location was the test carried out at exactly
 - iv) The report shall include the time, date and location of percolation tests. Show the start and end time the test started and length f time it took for the trial hole to drain 50% within 24 hours.
- **1.4** If a soakaway is proposed submit a drawing in plan and cross-sectional view showing design details of same as per BRE Digest 365 Standards. The soakaway shall have an overflow connection to the public surface water sewer.

Flood Risk

No Objection

• The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.

Water Services Planning Report

Dublin Regional Code of Practice for Drainage Works.

All works for this development shall comply with the requirements of the Greater

Water Report:
Referred to IW

Foul Drainage Report:
Referred to IW

Signed:

Adam Adderley-McCabe GE

Endorsed:

Brian Harkin SEE.

Date:

Date: