

Water Services Planning Report

Register Reference No.: SD22A/0325
Development: Extension of an existing warehouse by approximately 1,685sq.m and the addition of 1 loading dock, extension of existing loading yard and upgrade of 11 parking spaces for E.V charging, 2 spaces to accessible parking spaces, and the addition of 35 covered bicycle parking spaces all on a site of approximately 1.6 hectares in the townland of Fortunestown .

Location: 23, Magna Drive, Magna Business Park, Citywest, Dublin 24.

Report Date : 19th Sept 2022

Surface Water Report:

No objection subject to:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Adam Adderley-McCabe GE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____