

Water Services Planning Report

Register Reference No.: SD22A/0326
Development: Installation of 410 Solar PV Panels mounted on the roof of 1 existing industrial building and associated site works and services.

Location: Block 402, Grants Drive, Greenogue Business Park, Rathcoole, Co. Dublin

Report Date : 19th Sept 2022

Surface Water Report:

No objection subject to:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Adam Adderley-McCabe GE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____