Water Services Planning Report

Register Reference No.: Development:	<i>SD22A/0334</i> Two storey, three bed detached dwelling of approx. 110sq.m in the side garden of the existing dwelling; new vehicular entrance to the side of the site; new pedestrian entrance to the front of the site and all associated site works.
Location:	16, Fairways, Rathfarnham, Dublin 14, D14XR40
Report Date :	21 st Sept 2022

Surface Water Report: Further Information required:

1.1 There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.

1.2 The applicant is required to submit a revised drawing showing plan & crosssectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:

- i) At least 5m from any building, public sewer, road boundary or structure.
- ii) Generally, not within 3m of the boundary of the adjoining property.
- iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- v) Soakaways must include an overflow connection to the surface water drainage network.

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

<u>Water Report:</u> Foul Drainage Report:			Referred to IW Referred to IW
Endorsed:	Brian Harkin SEE	Date:	

Page 1 of 2

Water Services Planning Report