Connecting You to



Eldhose Varghese 32, Liffey Park Liffey Valley Park Lucan Dublin

Date : 11-Oct-2022

Reg. Ref. :	SD22B/0168/C3
Proposal :	Ground floor extension to side and rear of existing house and
	new dormer window in roof to the back of the house.
	Condition 3; Drainage - Surface Water.
	Prior to the commencement of development, the
	applicant/developer shall submit the following for the
	written agreement of the Planning Authority:
	1.1 The applicant is required to submit a report showing site
	specific soil percolation test results and design calculations
	for the proposed soakaway in accordance with BRE Digest
	365 – Soakaway Design.
	1.2 The applicant is required to submit a revised drawing
	showing plan and crosssectional views, dimensions, and
	location of proposed soakaway. Any proposed soakaway
	shall be located fully within the curtilage of the property and
	shall be:
	i) At least 5m from any building, public sewer, road
	boundary or structure.
	ii) Generally, not within 3m of the boundary of the adjoining
	property.
	iii) Not in such a position that the ground below foundations
	is likely to be adversely affected.
	iv) 10m from any sewage treatment percolation area and
	from any watercourse / floodplain.
	v) Soakaways must include an overflow connection to the
	surface water drainage network.
	1.3 Should a soakaway prove not to be feasible, then the
	applicant shall submit the following:
	a) Soil percolation test results demonstrating a soakaway is
	not feasible
	b) A revised surface water layout drainage drawing for the
	development showing the inclusion of alternative SuDS
	(Sustainable Drainage Systems) features.
	1.4 The Developer shall ensure that there is complete
	separation of the foul and surface water drainage for the
	proposed development.
	•

Comhairle Contae Átha Cliath Theas, Halla an Contae, Tamhlacht, Átha Cliath 24. South Dublin County Council, County Hall, Tallaght, Dublin 24. Tel: +353 1 414 9000 SMS: 086 173 1707 Email: info@sdublincoco.ie Ceangail 24/7 Connect 24/7 with Council information and services at www.southdublin.ie



1.5 All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Location :32, Liffey Park, Liffey Valley Park, Lucan, DublinApplicant :Eldhose VargheseApplication Type:Compliance with Conditions

Dear Sir/Madam,

I refer to your submission received on 11-Aug-2022 to comply with Condition No 3 of Permission No. SD22B/0168, in connection with the above.

In this regard I wish to inform you that the submission received is satisfactory.

Yours faithfully,

M.C.

for Senior Planner