

Water Services Planning Report

Register Reference No.: SD22A/0047 AI
Development: Two-storey 4 bedroom detached dwelling with vehicular access and 2 off-street, parking spaces and all associated site works at side garden plot.
Location: 41, Watermeadow Park, Oldbawn Tallaght, Dublin 24 D24CH7V
Report Date : 12th Oct 2022

Surface Water Report:

No objection Subject To:

Flood Risk

No Objection Subject To:

2.1 All floor levels shall be a minimum of 500mm above the highest know flood level for the site.

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Refferred to IW

Signed: _____
Brian Harkin SEE.

Date: _____

Endorsed: _____
Juliene Helbert SE.

Date: _____