

TOBIN Consulting Engineers
Block 10-4
Blanchardstown Corporate Park
Dublin
D15 X98N

Date: 19-Oct-2022

**PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING
REGULATIONS THEREUNDER**

Register Reference: SD21A/0167 Condition 3, 6, 13 and 14

Development: Construction of a gas fired power plant with an electrical output of up to 125MW with associated balance of plant, equipment and buildings including; an Engine Hall building with a height of 18.9m, comprising 6 gas engines and ancillary infrastructure; an Electrical Annex Building with a height of 18.7m; a Workshop building with a height of 5.1m; a Tank Farm building with a height of 5.68m; a Security hut with a height of 3.27m; an Exhaust Stack with a height of 31.8m; a Gas AGI including a kiosk with height of 3.3m; Radiator Coolers with a height of 8.46m; 2 electrical transformers with a height of 4.98m; Tanks including 2 x Diesel Oil Storage Tanks (volume of 2500m³ combined); SCR Urea Tank (26m³); Lube Oil Storage Tank (26m³); Lube Oil Maintenance Tank (26m³); Pilot Oil Tank (26m³); Fire Water Storage Tank (1000m³); Effluent Collecting Tank (26m³); Underground Surface Water Attenuation Tank (490m³); 2 new access onto the existing private road network with Profile Park; 12 parking spaces, footpaths, landscaping; fencing and all other associated site development plant and equipment and other works including surface water and foul wastewater drainage. An EIAR was submitted with this application.

Location: Profile Park, Baldonnel, Dublin 22

Applicant: Shane Minehane, Greener Ideas Limited 1, Seapoint Building, 44-45 Clontarf Road, Dublin 3

Application Type: Compliance with Conditions

Dear Sir/Madam,

With reference to the above, I wish to acknowledge receipt of your submission in compliance with condition (s) of the planning permission, received on 11-Oct-2022.

This submission will be considered in accordance with Section 34(5) of the Planning and Development Act 2000 (as amended).

Yours faithfully,

Z. McAuley
for **Senior Planner**