

Register Reference: SD22A/0379

Development: Change of use from office to creche use of No. 17 and combining proposed creche with existing creche at No 16 (Reg Ref S95A/0124), alterations to facilitate a single operator including; Provision of two interconnecting doors in party wall between No. 16 and No. 17; Provision of universal accessible WC's to No. 17; Provision of new rear door to No. 17 and closure of existing side door; Removal of rear party boundary wall to provide one play area; Minor internal alterations, and all associated site works.

Location: 16 & 17 Main Street, Rathfarnham, Dublin 14

Applicant: Lily Pad Creche and Montessori

Application Type: Permission

Planning Officer:

Development Summary: Change of use from office to childcare facility and combination of proposed crèche with existing creche.

Decision:

Noise pollution and air pollution restrictions will be necessary for the conversion phase.

The above proposal **is acceptable** to the Environmental Health Department subject to the following conditions:

Conversion Phase

Noise

1. To control, limit and prevent the generation of Environmental Noise Pollution from occurring the Environmental Health Department of South Dublin County Council, hereby informs you that :

The use of machinery, plant, or equipment (which includes pneumatic drills, generators and the movement on and off the site of construction vehicles) is NOT PERMITTED outside the following hours

- Before 07.00 hours on weekdays, Monday to Friday
- Before 09.00 hours on Saturdays.

- After 19.00 hours on weekdays, Monday to Friday.
- After 13.00 hours on Saturdays.
- Not permitted at any time on Sundays, Bank Holidays or Public Holidays.

Reason: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

Air Quality

During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

Reason: To contain dust arising from construction / demolition in the interests of public health and to prevent nuisance being caused to occupiers of buildings in the vicinity.

Notes to the Developer:

The applicant is strongly advised to consult with Tusla Child and Family Agency prior to the commencement of the development.

Gillian Wynne

Senior Environmental Health Officer

14th October 2022

David OBrien

Principal Environmental Health Officer

14th October 2022

