



Important Safety Notice: Damage to gas pipelines can result in serious injury or death. Gas network information is provided as a general guide. The exact location and depth of medium or low pressure distribution gas pipes must be verified on site by carrying out necessary investigations, including, for example, hand digging trial holes along the route of the pipe. Service pipes are not generally shown but their presence should always be anticipated.

High pressure transmission pipelines are shown in red. If a transmission pipeline is identified within 10m of any intended excavations then work must not proceed before GNI has been consulted. The true location and depth of a transmission pipeline must be verified on site by a representative of GNI. Contact can be made through 1850 427747.

All work in the vicinity of the gas network must be completed in accordance with the current edition of the Health and Safety Authority publication, "Code of Practice for Avoiding Danger from Underground Services" which is available from the Health and Safety Authority (1980 288 388) or can be downloaded at www.hsa.ie.

Legal Notice: Gas Networks Ireland (GNI) and its affiliates, accept no responsibility for the accuracy of information contained in this document including data concerning location and technical condition of the gas distribution and transmission network (the Information). The Information should not be relied on for accurate distance or depth of cover measurements.

Any representations and warranties, express or implied, are excluded to the fullest extent permitted by law. No liability shall be accepted for any loss or damage, including without limitation, direct, indirect or consequential loss, arising out of or in connection with the use or reuse of the Information.

Reproduced from the Ordnance Survey by permission of the Government.
Licence No. 3-3-34

- Aurora Telecom Duct
- Aurora Telecom Sub Duct
- Aurora Telecom Inserted Gas Pipe
- Aurora Telecom Querries - 01-8928166 (Office Hours)
- Aurora Network - Querries@gasnetworks.ie
- Aurora Telecom Emergency Only: 1850 427399 / 01 2030120

- Transmission Pipe (High Pressure)
- Transmission Pipe (Construction Issue)
- Distribution Pipe (Medium Pressure)
- Distribution Pipe (Low Pressure)
- Service Pipe (Medium Pressure)
- Service Pipe (Low Pressure)
- Strategic Pipe (Medium Pressure)
- Strategic Pipe (Low Pressure)
- Inserted
- Abandoned Pipe

- CP Test Point
- Cover (depth in metres)
- Pressure Monitor
- Protection (Slabbing)
- Protection (Sleeve)
- End Cap
- Hot Tap
- Installation
- Valve
- Service Terminator
- Tee
- Mains Verification**
- Transition

** Please contact GNI on 1850-427747 for specific information

DIAL BEFORE YOU DIG
1850 427747

In Emergency call 1850 28 50 50
Gas Networks Ireland

GAS NETWORK INFORMATION	
Description: test	
Location: 703679, 733119	
Plot Date: 28/09/2022 11:56	Scale: 1000 @ A3
Plotted By: 164	Ref ID: 164_26092022115613

RIAI

Registered Architect
2020

Architect Accredited in Conservation
G3

PSDP Accreditation
P

DESIGN

CLIENT: Dermot & Margaret Finerty

ADDRESS: 2 Haydens Park View
Lucan
Co. Dublin, K78 NY82

DRWG NO: M1633-S1-401

REV: -

TITLE: ESB Networks Map

SCALE: N.T.S @ A3

DATE: 29/09/2022

BRENNAN | FURLONG

VERNON HOUSE 2 VERNON AVENUE CLONTARF DUBLIN 3
01 8747410 studio@brennanfurlong.ie www.brennanfurlong.ie

Do not scale. Use quoted dimensions only. All dimensions to be centred on site. Any discrepancy between site and ground dimensions to be brought immediately to the attention of the client. Digital copies cannot be printed. Copy information to: info@brennanfurlong.ie