


Register Reference: SD22A/0349 **Date:** 29-Sep-2022
Development: Modifications to the existing main site entrance to comprise of minor realignment of the internal access road with adjusted road marking and roadside bollards; Removal of 3 existing security traffic arms; Installation of 3 new security traffic arms and installation of 3 underground lifting security road blockers together with associated communications and electrical services; Provision of 2 set-down only parking spaces and all associated site drainage and installation works.
Location: Dublin Google Data Centre, Grange Castle Business Park South, 22, Baldonnel Road, Dublin 22
Applicant: Google Ireland Limited
App. Type: Permission
Planning Officer: SARAH WATSON
Date Recd: 06-Sep-2022
Decision Due Date: 31-Oct-2022

Prior to commencement of any works in the public domain, and in order to comply with The Roads Act 1993 Section 13 Paragraph 10, a Road Opening Licence must be secured from South Dublin County Council, Roads Maintenance Department.

Description: Modifications to the existing main site entrance to comprise of minor realignment of the internal access road with adjusted road marking and roadside bollards; Removal of 3 existing security traffic arms; Installation of 3 new security traffic arms and installation of 3 underground lifting security road blockers together with associated communications and electrical services; Provision of 2 set-down only parking spaces and all associated site drainage and installation works.



Access & Roads Layout:

The proposed realignment of the internal access road with adjusted road marking and roadside bollards are deemed to be satisfactory by the roads department of SDCC, as is the provision of 2 set-down parking spaces with only AutoTRAK analysis required to prove the design of the realignment.

Roads recommend that additional information be requested from the applicant:

1. The applicant to provide AutoTRAK analysis for large vehicle movements accessing the site and passing safely through the proposed new road layout (2no. drawings required for both HGV and articulated truck movements).

Should the permission be granted, the following conditions are suggested:

1. All items and areas for taking in charge shall be undertaken to a taking in charge standard. Prior to development the applicant shall submit construction details of all items to be taken in charge. No development shall take place until these items have been agreed.
2. Prior to commencement of development, the applicant shall submit a developed Construction Traffic Management Plan for the written agreement of the Planning Authority
3. Prior to commencement a Public Lighting Design for the development must be submitted and agreed by the Public Lighting team of SDCC
4. Any road marking proposed and or to be installed shall comply with most up to date Chapter 7 (ROAD MARKINGS) of the Traffic Signs Manual.
5. Any road sign proposed and or to be installed shall comply with most up to date Chapter 6 (WARNING SIGNS) of the Traffic Signs Manual.
6. Any road sign proposed and or to be installed shall comply with most up to date Chapter 5 (REGULATORY SIGNS) of the Traffic Signs Manual.