

ENVIRONMENTAL HEALTH - PLANNING MEMO

Date: 25-Oct-2022

Register Reference: SDZ21A/0023

Development: 455 residential units (including a mixture of 2 and 3 storey semi-detached and terraced houses, and duplex units and apartments in 3 and 4 storey blocks), new internal roads and footpaths, site access, public open space, car parking, cycle stores, landscaping, bin stores, foul and surface water drainage, boundary walls and fences, ESB substations and all associated site development works. Private and semi-private open space to serve the proposed units will be provided in the form of balconies, terraces and gardens; including revisions to the permitted / under construction Celbridge Link Road (part of Loop Road 3), permitted under Reg. Ref SDZ17A/0009, associated with the provision of access to the development, parallel parking bays, and public lighting; 58 two bed, two storey, terraced houses (Type E1, E2, E3, J1 & J2); 6 three bed, two storey, semi-detached houses (Type 11); 190 three bed, two storey, terraced houses (Type A 1, A2, A3, B1, 82, C1, C2, C3, D1, D2, F1, F2, 11 & 12); 5 three bed, three storey, terraced houses (Type H); 6 four bed, two storey, terraced houses (Type K1, K2); 7 apartment Blocks (Blocks B, D, E, G, H, I & K) containing 111 apartments/duplexes including 32 one bed apartments, 22 two bed and 57 three bed duplex apartments over 3 storeys; 4 apartment Blocks (Blocks A, C, J & L) containing 37 apartments/duplexes including 8 no. one bed apartments, 29 three bed duplex apartments over 4 storeys; 1 apartment Block (Block F) containing 42 apartments including 2 one bed apartments and 40 two bed apartments over 4 storeys on a site located to the south of Tubber Lane, in the north-west of the Adamstown SDZ lands and to the west and south-west of the permitted/under construction Tubber Lane Phase 2 development (Reg. Ref: SDZ19A/0008, as amended under Reg. Ref: SDZ20A/0014).

Location: Tubber Lane, Adamstown, Lucan, Co. Dublin.

Applicant: Hugh McGreevy & Sons Ltd.

App. Type: SDZ Application

Planning Officer: SARAH WATSON

Date Received: 30-Sep-2022

Decision Due: 27-Oct-2022

Following examination of the additional information submitted by the applicant the proposal is acceptable to the Environmental Health Department. The following conditions should be applicable in the event of planning permission being granted:

1. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.

Any work outside of these hours shall only be permitted following a written request to the Planning Authority and subsequent receipt of the written consent of the Planning Authority, having regard to the reasonable justification and circumstances and a commitment to minimise as far as practicable any unwanted noise outside the hours stated above.

2. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
3. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.
4. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.
5. The applicant shall put in place a pest control contract for the site for the duration of the construction works.
6. The development shall be so operated that there will be no emissions of malodours, gas, dust, fumes or other deleterious materials, no noise vibration on site as would give reasonable cause for annoyance to any person in any residence, adjoining unit or public place in the vicinity.
7. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A) and shall not exceed the background level for evening and night time. Clearly audible and impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.

8. Signage or lighting to be used on site during both construction and the on-going operation of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.

Mark Whelan .

Mark Whelan
Environmental Health Officer



Kieran Groarke
Environmental Health Officer