

User input indicated by **Orange fields**

User Input

Zoning lookup

Minimum GI Score

OS

0.7

1. Enter Development Site Area m² **HERE** ▶

4625

Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m ²	Factor Values
1. Short Lawn	0.3	192	57.6
2. Tall Lawn (wild, not mown)	0.5	184	92
Permeable Paving	0.3	327	98.1
Vegetation		0	0
4a. Vegetation-Shrub below 3cm	0.4	478.17	191.268
4b. Vegetation-Shrub / Hedgerow above 3cm	0.5	1700	850
4c. Vegetation-Pollinator friendly perennial planting	0.5	184	92
4d. Vegetation-Preserved hedgerow	1.2	200	240
Trees		0	0
5a. New trees	0.6	300	180
5b. Preserved trees	1.2	1300	1560
7. SuDS intervention (rain garden, bioswale)	0.6	0	0
Green Roof		0	0
9a. Green Roofs- Intensive green roof (substrate is 1 metre or greater in depth)	0.7		0
9b. Green Roofs - Extensive green roof (less than 1 metre in depth)	0.6	0	0
10. Green wall	0.4	0	0
11. Retained Open Water	2	0	0
12. New open water	1.5		0
Total Equivalent Surface Area of Greening Factors		4,865.17	
	Green Factor Numerator	3360.97	
Minumum Required GI score	Final GI score	Result	
0.7	0.73	Pass	