

**Armstrong Fenton Associates
Unit 13, The Seapoint Building
44/45, Clontarf Road
Dublin 3**

Date : 15-Nov-2022

**Reg. Ref. :
Proposal :**

SD21A/0327/C17

A residential development of 77 dwellings comprised of 63 two storey houses and 14 apartments & duplex units accommodated in one 3 storey building. The proposed houses are comprised of 8 two bed houses & 55 three bed houses; the proposed apartments & duplex units are comprised of 7 one bed apartments at ground floor & 7 three bed duplex units overhead. The proposed development also provides for all associated site development & infrastructural works, car & bicycle parking, open spaces, hard & soft landscaping, boundary treatments and bin & bicycle storage; access to the development will be via a new vehicular entrance at the south-west corner of the site off the Old Naas Road. Permission is also sought to demolish the existing building on site approximately 455sq.m. all on a site area of 2.28Ha, at Gordon Park, Old Naas Road, Kingswood, Dublin 22 bounded to the west by the Old Nass Road, to the south by the Silken Park development and is located in the townland of Brownsbarn.

Condition 17. Drainage - Surface Water.

The disposal of surface water, shall fully comply with all of the technical requirements of the Council's Water Services Section. In this regard, prior to the commencement of development, the applicant/developer shall submit the following for the written agreement of the Planning Authority:

- (a) Fully detailed foul and surface water drainage plans for the proposed development as approved showing location of all manholes, AJs etc located within the site boundary up to and including point of connection to the public sewer that fully accords with the requirements Council's Water Services Section and or Irish Water,**
- (b) There shall be complete separation of the foul and surface water drainage systems, both in respect of installation and use. All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.**

(c) All drainage works for this development shall comply fully with the Greater Dublin Regional Code of Practice for Drainage Works.

Location : Gordon Park, Old Naas Road, Kingswood, Dublin 22
Applicant : Greenwalk Development Ltd.
Application Type: Compliance with Conditions

Dear Sir/Madam,

I refer to your submission received on 20-Sep-2022 to comply with Condition No 17 of Grant of Permission No. 17, in connection with the above.

In this regard I wish to inform you that the submission received is satisfactory.

Yours faithfully,

M.C. .

for Senior Planner