

**Irish Water's Statutory
Response to**

South Dublin

Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Planning Application No.

SD22A/0370

Date Lodged with Planning Authority:

26/09/2022

Development:

Installation of a 5.2m x 1.85m x 2.8m high stainless steel and glass bus shelter with 2 internally illuminated advertising panels each of 2sq.m area.

Location :

On the public footpath at Bus Stop No. 1322, Grange Road, Rathfarnham, Dublin 14

IW Recommendation:**Further Information Required****IW Observations:****1 Water (Further Information)**

1.1 Submit a drawing and report showing setback distances between the development and the existing 6 inch watermain.

Setback distances must comply with Irish Water "Water Infrastructure Standard Details" and the Greater Dublin Regional Code of Practices for Drainage Works.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul (No Objection)

Comply with Irish Water Standards in respect to setback distance of structure to foul sewers.

Reason: In the interest of public health and to ensure adequate waste water facilities.

Signed on Behalf of Irish Water:

Yvonne Haris

Date:

11/11/2022

