

Thomas O'Neill
4 Bridgecourt Office Park
Walkinstown Avenue
Dublin D12 Y981



15 November 2022

15.11.2022
15.11.2022
15.11.2022
15.11.2022

15.11.2022
15.11.2022
15.11.2022
15.11.2022

15.11.2022

Dear Thomas,

Re: Diversion Reference DIV22216 10A The Court, Cypress Downs, Dublin, D6WAH66

Irish Water has reviewed your enquiry in relation to a build near of Irish Water's water main and sewer as part of the proposed Development at 10A The Court, Cypress Downs, Dublin, D6WAH66 as indicated on drawing no. 5675-01 B.

Based upon the details you have provided with your enquiry and as assessed by Irish Water, we wish to advise you that, subject to the below conditions, the proposed build near can be facilitated.

A slit trench will be required prior to construction works commencing onsite and the Local Authority Water Services Inspector (acting as agents to Irish Water) shall witness the slit trench to determine the following:

- Exact location and separation distance of the existing watermain to the existing dwelling.

If you have any further questions, please contact Paul Roche from the diversions team on email diversions@water.ie. For further information, visit www.water.ie/connections.

Yours sincerely,

A handwritten signature in cursive script that reads "Yvonne Harris".

Yvonne Harris
Head of Customer Operations