

## ENVIRONMENTAL HEALTH - PLANNING MEMO

**Date:** 18-Nov-2022  
**Register Reference:** SD22A/0372  
**Development:** Demolition of existing two storey detached dwelling house and outbuildings; Construct new purpose built three storey mixed used building with, a new physiotherapy practice, consisting of 5 consultation rooms, office space, staff areas as well as a rehab gym and studio area, all over two floors at ground and first floor levels; One bedroom apartment with own door access and dedicated private balcony area at the second floor level; 5 car parking spaces and secure bicycle parking for 6 bicycles all on site; Back lit signage to the front facade of the building; All associated site development works.  
**Location:** Saint Claires Villa, Lucan Road, Lucan, Co. Dublin, K78 X0N1  
**Applicant:** John Shenton & Margaret Hanlon  
**App. Type:** Permission  
**Planning Officer:** CONOR DOYLE  
**Date Received:** 28-Sep-2022  
**Decision Due Date:** 22-Nov-2022

The proposal is **acceptable** to Environmental Health subject to the following conditions set out below:

1. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.
2. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
3. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.
4. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.

5. The applicant shall put in place a pest control contract for the site for the duration of the construction works.
6. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A).
7. Any connections to the main sewer must be connected so as not to give rise to a public health nuisance.
8. Signage or lighting to be used on site during both construction and the on-going operation of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.
9. Clearly audible or impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.

*Mark Whelan .*

Mark Whelan  
Environmental Health Officer



---

Kieran Groarke  
Environmental Health Officer