

Telephone: 01 4149000 Fax: 01 4149104 Email: planningdept@sdublincoco.ie

F & D Studio Architects c/o Michael Frain 43 Downpatrick Road Dublin 12

# NOTIFICATION TO GRANT PERMISSION & GRANT RETENTION PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING REGULATIONS THEREUNDER

Final Grant Order No.:	1302	Date of Final Grant:	17-Oct-2022
Decision Order No.:	1126	Date of Decision:	05-Sep-2022
Register Reference:	SD22B/0324	Date:	11-Jul-2022

**Applicant:** Anne Donnelly

**Development:** The development consists of alterations to the former boundary wall and

pedestrian entrance to creating a new vehicular access /

entrance 3.5m wide and additional side pedestrian entrance and permission to

complete with the addition of gates and all associated

alterations, siteworks and ancillary works

**Location:** 9 Dodderdale, Rathfarnham, Dublin 14

Time extension(s) up to and including: Additional Information Requested/Received:

A Permission has been granted for the development described above, subject to the following conditions.

### **Conditions and Reasons:**

Development in accordance with submitted plans and details.
 The proposed development shall be carried out (and retained development shall be retained) and completed in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto. REASON: To ensure that the development shall be in accordance with the permission, and that effective control be maintained.

#### 2. Finishes.

The pillars, gates and fencing shall harmonise in colour and texture with the existing pillars and fencing in the immediate vicinity. Details of same shall be submitted to the Planning Authority for written agreement and such agreed details shall be fully implemented on site within one year of the date of final grant of permission.

REASON: In the interest of visual amenity.

#### 3. Gates.

No gate to be installed or erected shall be capable of opening across any public footpath, cycle-track, roadway or right of way, and any front entrance pillars shall be a maximum height

of 1.2m.

REASON: In the interests of visual amenity and pedestrian safety.

4. Drainage - Surface Water.

The disposal of surface water, shall fully comply with all of the technical requirements of the Council's Water Services Section. In this regard, prior to the commencement of development, the applicant/developer shall submit the following for the written agreement of the Planning Authority:

- (a) Fully detailed foul and surface water drainage plans for the proposed development as approved showing location of all manholes, AJs etc located within the site boundary up to and including point of connection to the public sewer that fully accords with the requirements Council's Water Services Section and or Irish Water,
- (b) There shall be complete separation of the foul and surface water drainage systems, both in respect of installation and use. All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
- (c) All drainage works for this development shall comply fully with the Greater Dublin Regional Code of Practice for Drainage Works.
- (d) The soakaway design to be submitted shall be certified to BRE Digest 365 standard by a suitably qualified person carrying professional indemnity insurance and shall include documented evidence of infiltration test results to demonstrate that the soakaway complies with the requirements of BRE Digest 365.

The revised plans shall provide for a soakaway to be located within the curtilage of the property and this shall be:

- (i) at least 5m from any buildings, public sewers or structures and not in such a position that the ground below foundations is likely to be adversely affected.
- (ii) at least 5m from the nearest road boundary and not within 3m of the boundary of the adjoining site.
- (iii) a minimum of 10m from any sewage treatment percolation area.
- (iv) at least 10m from any stream / river / flood plain.

In addition only rainwater shall be discharged to soakaways.

REASON: In the interests of public health, safety, the proper planning and sustainable development of the area and in order to ensure adequate and appropriate surface water drainage provision.

## **NOTES:**

NOTE: The applicant is advised that under the provisions of Section 34 (13) of the Planning and Development Act 2000 (as amended) a person shall not be entitled solely by reason of a permission to carry out any development.

NOTE: Notwithstanding any grant of planning permission; if an applicant requires permission to access local authority land (e.g. public footpaths, public open space or roadways) in order to access utilities, or for any other reason; please apply via

https://maproadroadworkslicensing.ie/MRL/ for a licence from the Local Authority to carry out those works.

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1997.
- (2) Building Control Regulations require a Commencement Notice. Please log onto <a href="https://www.localgov.ie">www.localgov.ie</a> and click on BCMS link.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.

(4) Free Standing Walls must be designed and construor of Practice for use of Masonry Part 1: Structural to Owner must also ensure that the construction of all person.		use of reinforced Masonry. The	
Signo	ed on behalf of South Dublin County Council.	M. Crowley	17 Oct 202

for Senior Planner