

Water Services Planning Report

Register Reference No.: SD22A/0371
Development: Internal modifications and single storey extension to the existing classrooms and SEN Unit at the south west corner of the campus to provide additional SEN accommodation, including a single storey Resource Room Extension in the south east corner.

Location: Scoil Naomh Aine, New Road, Clondalkin, Dublin 22

Report Date : 9th November 2022

Surface Water Report: **Additional information required:**

1.1 The applicant has not proposed any SuDS (Sustainable Drainage Systems) features for the proposed development. The applicant is required to submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development. SuDS features could include but are not limited to:

- Green roofs
- Water Butts
- Rain garden
- Other such SuDS

Flood Risk

- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

No Objection

Water Report:

Refer to IW

Foul Drainage Report:

Refer to IW

Signed: _____
Adam Adderley-McCabe GE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____